

# Parameter estimation of physical models for application in building control

K.U.Leuven, Belgium

Department of Mechanical Engineering

Lieve Helsen, Clara Verhelst

# Outline


- Introduction
- Framework of Model Predictive Control
- Development of control relevant model
- Applications in building control



# INTRODUCTION


# Introduction

- Model predictive control (MPC) of ground coupled heat pump systems



# Introduction


## ■ Control of traditional heating systems



Room thermostat

# Introduction


## ■ Control of low temperature heating systems



Heating curve

# Introduction

## ■ Heating curve ~ static building model



Tuning parameters:

- **Slope** proportional to heat losses =  $UA (T_{\text{room}} - T_{\text{ambient}})$
- **Offset** depends on set point  $T_{\text{room}}$
- **$\Delta T_{\text{stat}}$**  depends on heat gains (internal and solar)

# Introduction

## ■ Control of heating & cooling systems




Figure 6. Different uncertainties in heat gains: a) Low, b) Medium, c) High.




## Rule based control

Source: Werner et al., 2005



# Introduction

## ■ Traditional control hierarchy






PID –control  $T_{\text{supply}}$

Compressor power  
Circulation pumps  
Switching valves

# Introduction

## ■ MPC in the control hierarchy




PID –control  $T_{\text{supply}}$

Compressor power  
Circulation pumps  
Switching valves

# Introduction


## ■ Example 1: Condensing boiler






Optimal control objectives

# Introduction

## ■ Example 1: Condensing boiler



Building model  
 $T_{\text{zone}} = f(T_{\text{amb}}, Q)$



Optimal control formulation

$$\dot{Q}^* = \arg \min_u \int_0^{H_c} \dot{Q}(t) dt$$

subject to:


$$\dot{T}_{\text{zone}} = f(T_{\text{zone}}, T_{\text{amb}}, \dot{Q})$$

$$T_{\min}(t) \leq T_{\text{zone}}(t) \leq T_{\max}(t)$$

$$0 \leq \dot{Q}(t) < \dot{Q}_{\max}$$


# Introduction

## ■ Example 1: Condensing boiler



# Introduction

## ■ Example 2: Air-to-water heat pump system




Optimal control objectives

$$COP = \frac{\dot{Q}_c}{P} = f(T_{amb}, T_{supply})$$

# Coefficient of performance (COP)

$$COP = \frac{\dot{Q}_{supply}}{P_{compressor}}$$

$$COP_{max} = \frac{T_{supply}}{T_{supply} - T_{source}}$$




$$COP \approx (c_0 + c_1 T_{source} + c_2 T_{supply})$$

# Introduction





## ■ Example 2: Air-to-water heat pump system

- Guaranteed thermal comfort
- Minimal electricity demand





# Introduction




Building model  
 $T_{supply}, T_{zone} = f(T_{amb}, Q)$

Heat pump model  
 $COP = f(T_{amb}, T_{supply})$


# Introduction

## ■ Example 3: Ground coupled heat pump system




# Introduction


- Extra control objectives
  - Constraints on ground temperature





- Long-term sustainability



# Introduction



# Introduction




Building model  
 $T_{supply}, T_{zone} = f(T_{amb}, Q)$

Heat pump model  
 $COP = f(T_{brine}, T_{supply})$

Brine water model  
 $T_{brine} = f(T_{ground}, Q)$

# Introduction

## ■ Example 3: Ground coupled HP system



# Introduction

## ■ Needed: Building model...



Source: [www.groundMed.eu](http://www.groundMed.eu)

# Introduction

## ■ Heating system model...



Source: Remeha




# Introduction

## ■ Borefield model...



Source: [www.groundreach.eu](http://www.groundreach.eu)



Source: [www.geo4va.vt.edu](http://www.geo4va.vt.edu)



## Why do we need a model for control?

- Case studies: heating and cooling systems
  - Fast reacting systems, conventional control → static model
  - Slow reacting systems, model predictive control → dynamic model
  - Opportunities for optimization

# Outline


- Introduction
- **Framework of Model Predictive Control**
- Development of control relevant model
- Applications in building control

A photograph of a worker in a white protective suit climbing a ladder to install a yellow frame on a white structure. The worker is positioned at the top of the ladder, which is leaning against a white vertical post. The yellow frame is being installed on top of the post. Another person is visible at the base of the ladder, looking up. The background is a cloudy sky.

# MPC FRAMEWORK


# MPC framework

## ■ MPC in general



- Dynamic models used in MPC
  - Step response functions
  - Impulse response functions
  - Transfer functions
  - State space models
  - Ordinary Differential Equations
- Model complexity
  - Number of states
  - Nonlinearities
  - → “Not more complex than strictly needed”

## ■ Physical versus blackbox models



Blackbox	Physical
No (less) prior knowledge required	Prior knowledge required
Selection blackbox model structures	Formulation system equations
Parameters no physical meaning	Parameters physical meaning
Only input-output relation	Physical insight in process
No extrapolation	Extrapolation

# MPC framework



## ■ Model types

- Step response functions
- Impulse response functions
- Transfer functions
- State space models
- Ordinary Differential Equations

Physical models

## ■ Model complexity


- Number of states
- Nonlinearities
- → “Not more complex than strictly needed”

Focus in this lecture




# MPC framework

## ■ Development of control relevant model



# Outline

- Introduction
- MPC Framework
- Development of control relevant model
  - Physical modelling
  - Model structure selection
  - Parameter estimation procedure
  - Model validation
  - Control performance evaluation
- Applications in building control



# References

- Maciejowski, J. M., Ed. (2002). Predictive control: with constraints. Pearson Education. Great Britain.




# DEVELOPMENT OF CONTROL RELEVANT MODEL

# Development of a control relevant model

- Step 1: Define system boundaries
- Step 2: Select model structure
- Step 3: Identify model parameters
- Step 4: Validate model
  - If bad fit: Try better identification data
  - If still bad fit: Try other model structure
- Step 5: Evaluate control performance


# Development of a control relevant model

- Steps 1 & 2: Model structure selection




# Development of a control relevant model

## ■ Step 3: Parameter estimation



# Development of a control relevant model


## ■ Step 4: Validation






# Development of a control relevant model

## ■ Technical issues




# Development of a control relevant model

## ■ Step 5: Control performance evaluation




# Development of a control relevant model

## □ Step 5: Is the expected control performance achieved?




# Development of a control relevant model

□ Step 5: Is the expected control performance achieved?




# Development of a control relevant model

□ Step 5: Is the expected control performance achieved?



# Development of control relevant model

## ■ Summary



# Outline

- Introduction
- Framework of Model Predictive Control
- Development of control relevant model
- **Applications in building control**

# Applications in building control



- Applications in building control
  - Heating curve control
  - MPC for heavy-weight solar building
  - MPC for heat pump system with floor heating
  - MPC for ground coupled heat pump system
  - MPC for multizone building





# Heating curve example

## 1. Control objective




## 2. Physical model

$$C_z \frac{dT_{zone}}{dt} = \dot{Q}_{rad} + \dot{Q}_{gains} - \dot{Q}_{loss}$$

$$\rightarrow \dot{Q}_{rad} = UA_{rad}(\bar{T}_{water} - T_{zone})$$

$$\rightarrow \dot{Q}_{loss} = UA_{building}(T_{zone} - T_{amb})$$



### Assume steady-state

$$\dot{Q}_{rad} + \dot{Q}_{gains} - \dot{Q}_{loss} = 0$$



$$\bar{T}_w = T_z + \frac{UA_{building}}{UA_{rad}} (T_z - (T_{amb} + \Delta T_{stat}))$$

# Heating curve example


## ■ 3. Model structure

- linear, algebraic equation
- 2 parameters

$$\bar{T}_w = T_z + \frac{UA_{building}}{UA_{rad}} (T_z - (T_{amb} + \Delta T_{stat}))$$

## ■ 4. Parameter identification


### □ Identification data



# Heating curve example

## ■ 4. Parameter estimation

### □ Identification data



### □ Measurement setup

#### ■ Selection:

- Measured variables  $\{ T_{\text{supply}}, T_{\text{return}}, T_{\text{floor}}, T_{\text{zone}}, T_{\text{amb}}, Q \}$
- Measurement period
- Sampling frequency

#### ■ Be aware of measurement noise!

# Heating curve example

## ■ 4. Parameter estimation

### □ Model structure

$$\bar{T}_w = T_z + \frac{UA_{building}}{UA_{rad}} (T_z - (T_{amb} + \Delta T_{stat}))$$

### □ Identification data


→  $m$  measurements  $T_{water}$ ,  $T_{zone}$ ,  $T_{amb}$

### □ Linear regression

$$\begin{bmatrix} \bar{T}_{water}(0) - T_{zone}(0) \\ \vdots \\ \bar{T}_{water}(m) - T_{zone}(m) \end{bmatrix} = \begin{bmatrix} T_{zone}(0) - T_{amb}(0) & 1 \\ \vdots & \vdots \\ T_{zone}(m) - T_{amb}(m) & 1 \end{bmatrix} \begin{bmatrix} \theta_1 \\ \theta_2 \end{bmatrix}$$

$$\varphi = X\theta$$

$$\theta^* = (\varphi' \varphi)^{-1} \varphi' X$$



$$\text{with } \begin{cases} \theta_1 = \frac{UA_{building}}{UA_{rad}} \\ \theta_2 = \frac{UA_{building}}{UA_{rad}} \Delta T_{stat} \end{cases}$$

## ■ Least squares


### □ Optimal estimator

$$e(t) = \hat{y}(t, \theta) - y(t)$$

$$E\{e(t)\} = 0$$

$$E\{e(t)' e(t)\} = \Lambda$$

$$\theta^* = \arg \min E \left\{ \frac{e(t)' e(t)}{\Lambda} \right\}$$



### □ In case only white noise at output

$$E\{e(t)\} = 0$$

$$E\{e(t)' e(t)\} = \sigma^2 I$$

$$\theta^* = \arg \min E \left\{ \sum_{n_y} \frac{e_i(t)' e_i(t)}{\sigma_i^2} \right\}$$



### □ ... If also linear in parameters

$$\theta^* = (\varphi' \varphi)^{-1} \varphi' X$$

# Heating curve example


## ■ 5. Model validation

- “Expected steady state behavior?”




Validation input data

$U_{\text{val}}$



Advanced HVAC Control, September 2010, Prague




System response

$Y_{\text{val}}$

# Heating curve example

## ■ 6. Evaluate control performance



- If unsatisfactory... Maybe static building model not appropriate?

# Heating curve example


## ■ Discussion: static versus dynamic control model

□ From  $m$  steady state measurements  $T_{water}$ ,  $T_{zone}$ ,  $T_{amb}$

→ static model

□ If also *transient data* measured:

→ dynamic model




$$\frac{dT_{zone}}{dt} = \frac{UA_{rad}}{C_{zone}} (\bar{T}_{water} - T_{zone}) + \frac{UA_{building}}{C_{zone}} (T_{zone} - (T_{amb} + \Delta T_{stat}))$$

$$\begin{bmatrix} T_{zone}(1) - T_{zone}(0) \\ \vdots \\ T_{zone}(m) - T_{zone}(m-1) \end{bmatrix} = \Delta t_s \begin{bmatrix} \bar{T}_{water}(0) - T_{zone}(0) & T_{zone}(0) - (T_{amb}(0) - \Delta T_{stat}) \\ \vdots & \vdots \\ \bar{T}_{water}(m) - T_{zone}(m) & T_{zone}(m-1) - (T_{amb}(m-1) - \Delta T_{stat}) \end{bmatrix} \begin{bmatrix} \theta_4 \\ \theta_5 \end{bmatrix}$$




# Heating curve example

## ■ Discussion: static versus dynamic control model



## ■ Implications

- Too quick: static model
- Too slow: constant value
- In between: dynamic model



# Outline

- Introduction
- Framework of Model Predictive Control
- Development of control relevant model
- Applications in building control

# Applications in building control


- Applications in building control
  - Heating curve control
  - MPC for heavy-weight solar building
  - MPC for heat pump system with floor heating
  - MPC for ground coupled heat pump system
  - MPC for multizone building



# Solar building example

## ■ 1. Control objective

- Thermal comfort in heavy-weight building with radiators



Single zone with radiator




Figure 3-3: PPD and PMV with variable clothing

Objective: thermal comfort




Control variables – Controlled variables

# Solar building example

## ■ 1. Control objective

### □ Control of thermal comfort in single-zone with radiators



Single zone with radiator




Figure 3-3: PPD and PMV with variable clothing


Objective: thermal comfort

Control variable – Controlled variables


# Solar building example

## ■ 1. Control objective

- Control of thermal comfort in single-zone with radiators



Single zone with radiator




Dynamics of interest

Control variables – Controlled variables


# Solar building example

## ■ 1. Control objective

- Control of thermal comfort in single-zone with radiators



$$T_{op} = \frac{1}{2} \left( T_{air} + \frac{A_i T_{surf,i}}{A_{tot}} \right)$$



Control variable – Controlled variables

# Solar building example

## ■ 2. Physical model

Most dynamic effects in building thermal behaviour are related to transient heat transfer through walls or slabs. Section 2.2 will be devoted to the problem of finding a simplified model for a multi-layer wall.

Source: Kummert 2001

### □ Heat transport through walls

$$\frac{\partial T}{\partial t} = \alpha \frac{\partial^2 T}{\partial x^2} \quad \text{with} \quad \alpha = \frac{k}{\rho c_p} \quad (\text{m}^2/\text{s})$$

Heat diffusion equation: Fourier's law



Partial Differential equation (PDE)  
Continuous in space (x) and time (t)




# Solar building example

## □ Wall model


### ■ Analytical solution heat diffusion equation

$$\frac{\partial T}{\partial t} = \alpha \frac{\partial^2 T}{\partial x^2} \quad \theta(x^*) = \sum_{n=1}^{\infty} C_n \exp(-\zeta_n^2 Fo) \cos(\zeta_n x^*) \quad \text{with } Fo = \frac{\alpha t}{R^2}$$

### ■ Simplification 1: Discretization in space




$T(x, t)$



$T_1(t) \quad T_2(t) \quad T_3(t)$

‘lumped capacitances’



‘RC-network representation’

# Solar building example

## □ Wall model

### ■ Boundary conditions at surface


□ Convection  $\dot{Q}_{conv} = UA(T_{w,surf} - T_{air})$  with  $U = f(T_{air}, \dot{m}_{air})$

□ Radiation  $\dot{Q}_{rad,ij} = \varepsilon\sigma(T_{w,surf,i}^4 - T_{w,surf,j}^4)$


□ → Nonlinear processes!

### ■ Simplification 2: Linearization


□  $\dot{Q}_{tot} = UA(T_{w,surf} - T_{air})$  with  $U = c^{te}$



## ■ Convex versus non-convex optimization problems




$$\begin{aligned} \min x^T A x \\ Bx \leq b \end{aligned}$$



$$\begin{aligned} \min f(x) \\ g(x) \leq 0 \end{aligned}$$

## ■ Convex versus non-convex optimization problems



# Solar building example

## ■ 3. Proposed model structures

Our objective is to obtain a more accurate wall model than the one obtained with Laret's approach but staying at an acceptable level of complexity to be included in a simplified thermal zone model suitable for the development of a model-based controller. A model with about ten nodes or more, as the ones obtained by following the approach of (Waters and Wright, 1985), would certainly not be suitable.





Figure 2-1: Wall lumped capacitance models with 1, 2 and 3 nodes and boundary conditions

# Solar building example

## 3. Proposed model structures

### Model equations



$$\begin{pmatrix} \dot{T}_1 \\ \dot{T}_2 \\ \dot{T}_3 \end{pmatrix} = \begin{pmatrix} -\left(\frac{1}{R_1 C_1} + \frac{1}{(R_0 + UA_0^{-1})C_1}\right) & \frac{1}{R_1 C_1} & 0 \\ \frac{1}{R_1 C_2} & -\left(\frac{1}{R_1 C_2} + \frac{1}{R_2 C_2}\right) & \frac{1}{R_2 C_2} \\ \frac{1}{R_2 C_3} & -\left(\frac{1}{R_2 C_3} + \frac{1}{(R_3 + UA_3^{-1})C_3}\right) & 0 \end{pmatrix} \begin{pmatrix} T_1 \\ T_2 \\ T_3 \end{pmatrix} + \begin{pmatrix} \frac{1}{(R_0 + UA_0^{-1})C_1} & 0 \\ 0 & 0 \\ 0 & \frac{1}{(R_3 + UA_3^{-1})C_3} \end{pmatrix} \begin{pmatrix} T_{air} & T_{amb} \end{pmatrix}$$



$$\dot{T} = AT + Bu$$

# Solar building example

## ■ 3. Parameter estimation

### □ Model parameters

$$\begin{pmatrix} \dot{T}_1 \\ \dot{T}_2 \\ \dot{T}_3 \end{pmatrix} = \begin{pmatrix} -\left(\frac{1}{R_1 C_1} + \frac{1}{(R_0 + UA_0^{-1})C_1}\right) & \frac{1}{R_1 C_1} & 0 \\ \frac{1}{R_1 C_2} & -\left(\frac{1}{R_1 C_2} + \frac{1}{R_2 C_2}\right) & \frac{1}{R_2 C_2} \\ \frac{1}{R_2 C_3} & -\left(\frac{1}{R_2 C_3} + \frac{1}{(R_3 + UA_3^{-1})C_3}\right) & 0 \end{pmatrix} \begin{pmatrix} T_1 \\ T_2 \\ T_3 \end{pmatrix} + \begin{pmatrix} \frac{1}{(R_0 + UA_0^{-1})C_1} & 0 \\ 0 & 0 \\ 0 & \frac{1}{(R_3 + UA_3^{-1})C_3} \end{pmatrix} \begin{pmatrix} T_{air} & T_{amb} \end{pmatrix}$$



$$\begin{pmatrix} \dot{T}_1 \\ \dot{T}_2 \\ \dot{T}_3 \end{pmatrix} = \begin{pmatrix} -(\theta_1 + \theta_2) & \theta_1 & 0 \\ \theta_3 & -(\theta_3 + \theta_4) & \theta_4 \\ \theta_5 & -(\theta_5 + \theta_6) & 0 \end{pmatrix} \begin{pmatrix} T_1 \\ T_2 \\ T_3 \end{pmatrix} + \begin{pmatrix} \theta_2 & 0 \\ 0 & 0 \\ 0 & \theta_6 \end{pmatrix} \begin{pmatrix} T_{air} & T_{amb} \end{pmatrix}$$

### □ Initial guess for $\theta$

- from known thermodynamic properties


# Solar building example

## ■ 3. Parameter estimation

### □ Initial guess parameters

#### ■ Homogeneous wall - single node

- $C = \rho c_p X \quad \left( \frac{\text{J}}{\text{m}^2 \text{K}} \right)$
- $R_0 = \frac{rX}{k} \quad \left( \frac{\text{Km}^2}{\text{W}} \right)$
- $R_1 = \frac{(1-r)X}{k} \quad \left( \frac{\text{Km}^2}{\text{W}} \right)$



- $\rightarrow$  1 optimization variable,  $r$   
How to define?



# Solar building example

## ■ 3. Parameter estimation

### □ Optimize model parameter $r$

#### ■ Needed:

1. Real system/ Reference model
2. Identification data set
3. Measure for model error
4. Optimization criterion
5. Optimization method

Reference simulation model:  
Finite Difference Model



# Solar building example

## ■ 3. Parameter estimation


### □ Optimize model parameter $r$

#### ■ Needed:

1. Reference model
2. Identification data set
3. Measure for model error
4. Optimization criterion
5. Optimization method



Step input



Step response

→ Response of  $T_{surf,1}$  and  $T_{surf,2}$  to step change in  $T_{air}$

## ■ 3. Parameter estimation

### ■ Optimize model parameter $r$

#### □ Needed:

1. Reference model
2. Identification data
3. Measure for model error
4. Optimization criterion
5. Optimization method

$$e_1(t) = (T_{surf,1,mod} - T_{surf,1,FD})$$

$$e_2(t) = (T_{surf,2,mod} - T_{surf,2,FD})$$


$$SSE_1 = \int_0^{t_m} (e_1^T e_1) dt$$

$$SSE_2 = \int_0^{t_m} (e_2^T e_2) dt$$

# Solar building example

## 3. Parameter estimation

### Optimize model parameter $r$




Exhaustive search

# Solar building example

## 3. Parameter estimation

### Optimize model parameter $r$



Exhaustive search


# Solar building example

## ■ 3. Parameter estimation

□ Analogously: determine parameters of

■ RC2-model


■ RC3-model



# Solar building example

## ■ 4. Model validation

### □ Time domain




Step response  $T_{surf,1}$   
Concrete wall

# Solar building example

## ■ 4. Model validation

### □ Time domain





Step response  $T_{surf,2}$   
Concrete wall



# Solar building example

## ■ 4. Model validation

### □ Frequency domain



Bode plot for  $T_{surf,1}$  with respect to excitation  $T_{air}$   
Concrete wall



Frequency range of interest

- Frequency range solar gains
- Frequency range internal gains


# Solar building example

## 5. Model selection

- “As simple as possible”
- “But accurate enough”




Step response  $T_{surf,1}$



Step response  $T_{surf,2}$

# Solar building example

## ■ Resulting model for single-zone



**Scheme of the simplified thermal zone model**

# Solar building example

## ■ Take home message

- Step 1: Define control objectives
- Step 2: Determine controlled variables and control variables  
→ model inputs and outputs
- Step 3: Write down system equations
  - Discretization in space
  - Linearization→ model structure(s) with parameters
- Step 4: Initial parameter estimate from physical insight
- Step 5: Parameter estimation
- Step 6: Model validation
- Step 7: Model selection

# References

- Kummert, M. (2001). **Contribution to the application of modern control techniques to solar buildings.** Simulation-based approach and experimental validation, Ingénieur Civil mécanicien - électricien. Liège, Fondation Université Luxembourgeoise, p. 260.

# Applications in building control

- Applications in building control
  - Heating curve control
  - MPC for heavy-weight solar building
  - MPC for heat pump system with floor heating
  - MPC for ground coupled heat pump system
  - MPC for multizone building



# Online system identification example



# Online system identification example

## ■ System



- Heavy-weight building
- Floor heating
- Heat pump system

## ■ Control objectives

- Minimize thermal discomfort & electricity cost

$$J(\dot{Q}_{hp}) = \frac{\Delta t_{s,MPC}}{2} \sum_{k=0}^N \left\{ R_k \left( \frac{c_{el,k}}{COP_k} \dot{Q}_{hp,k} \right)^2 + (T_{zone,k} - T_{zone,k}^{ref})^2 \right\}$$

## ■ Required model






# Online system identification example


## ■ Available measurements

□  $T_{\text{supply}}$ ,  $T_{\text{return}}$ ,  $T_{\text{amb}}$ ,  $Q_{\text{hp}}$



# Online system identification example


## ■ Physical model 1



3<sup>rd</sup> order model

# Online system identification example

## ■ Physical model 2



2<sup>nd</sup> order model

# Online system identification example

## ■ Model equations

### □ 3<sup>rd</sup> order model

$$\begin{bmatrix} \dot{T}_{return}(t) \\ \dot{T}_{floor}(t) \\ \dot{T}_{zone}(t) \end{bmatrix} = \begin{bmatrix} -\frac{k_{wf}}{\rho_w c_w V_w} & \frac{k_{wf}}{\rho_w c_w V_w} & 0 \\ \frac{k_{wf}}{m_f c_f} & -\frac{k_{wf} + k_{fz}}{m_f c_f} & \frac{k_{fz}}{m_f c_f} \\ 0 & \frac{k_{fz}}{\tau_b k_b} & -\frac{k_{fz} + k_b}{\tau_b k_b} \end{bmatrix} \begin{bmatrix} T_{return}(t) \\ T_{floor}(t) \\ T_{zone}(t) \end{bmatrix} + \begin{bmatrix} 0 & \frac{1}{\rho_w c_w V_w} \\ 0 & 0 \\ \frac{1}{\tau_b} & 0 \end{bmatrix} \begin{bmatrix} T_{amb}(t) + \Delta T_{stat} \\ \dot{Q}_{hp}(t) \end{bmatrix}$$

6 parameters

### □ 2<sup>nd</sup> order model

$$\begin{bmatrix} \dot{T}_{return}(t) \\ \dot{T}_{zone}(t) \end{bmatrix} = \begin{bmatrix} -\frac{k_{wz}}{\rho_w c_w V_w} & \frac{k_{wz}}{\rho_w c_w V_w} \\ \frac{k_{wz}}{k_b \tau_b} & -\frac{k_{wz} + k_b}{k_b \tau_b} \end{bmatrix} \begin{bmatrix} T_{return}(t) \\ T_{zone}(t) \end{bmatrix} + \begin{bmatrix} 0 & \frac{1}{\rho_w c_w V_w} \\ \frac{1}{\tau_b} & 0 \end{bmatrix} \begin{bmatrix} T_{amb}(t) + \Delta T_{stat} \\ \dot{Q}_{hp}(t) \end{bmatrix}$$

4 parameters

# Online system identification example

## ■ Parameter estimation

### □ Problems!

- Real data
  - measurement errors on:
    - input variables
    - output variables
- Non-measured inputs:
  - Solar gains
  - Internal gains
- Non-measured states
  - more unknown variables

noise

Unmodelled  
disturbances

Proces  
simplification

# Online system identification example

## ■ Requirements for identification

- Based on online measurement data

- Robust with respect to:

  - Modeling errors

  - Noise

- Recognition of solar gains

- Physically meaningful parameters

- Good prediction of building thermal behaviour for a time horizon of 24 hours

# Implications of existence of noise

## ■ In ideal case

- No noise
- Perfect model knowledge

## ■ Then

- If excitation is persistent
  - Parameters are uniquely defined
  - Solution not dependent on excitation signal
- Number of equations needed = number of parameters

**Deterministic problem**

# Implications of existence of noise

## ■ Deterministic solution

### □ Example 2<sup>nd</sup> order model (MISO)

$$\begin{bmatrix} \dot{T}_{return}(t) \\ \dot{T}_{zone}(t) \end{bmatrix} = \begin{bmatrix} -\frac{k_{wz}}{\rho_w c_w V_w} & \frac{k_{wz}}{\rho_w c_w V_w} \\ \frac{k_{wz}}{k_b \tau_b} & -\frac{k_{wz} + k_b}{k_b \tau_b} \end{bmatrix} \begin{bmatrix} T_{return}(t) \\ T_{zone}(t) \end{bmatrix} + \begin{bmatrix} 0 & \frac{1}{\rho_w c_w V_w} \\ \frac{1}{\tau_b} & 0 \end{bmatrix} \begin{bmatrix} T_{amb}(t) + \Delta T_{stat} \\ \dot{Q}_{hp}(t) \end{bmatrix}$$



$$T_R(t) - 2T_R(t-1) + T_R(t-2) = \begin{bmatrix} (T_R(t-1) - T_R(t-2))t_s \\ (Q_{hp}(t-1) - Q_{hp}(t-2))t_s \\ T_R(t-2) - T_{amb}(t-2)t_s^2 \\ Q_{hp}(t-2)t_s^2 \end{bmatrix}^T \begin{bmatrix} \theta_1 \\ \theta_2 \\ \theta_3 \\ \theta_4 \end{bmatrix}$$

with

$$\theta_1 = -\frac{k_{wz}}{\rho_w c_w V_w} - \frac{k_{wz} + k_b}{k_b \tau_b} \quad \theta_2 = \frac{1}{\rho_w c_w V_w} \quad \theta_3 = \frac{k_{wz}}{\rho_w c_w V_w \tau_b} \quad \theta_4 = \frac{k_{wz} + k_b}{\rho_w c_w V_w \tau_b k_b}$$



# Implications of existence of noise

## ■ Deterministic solution

### □ Example 2<sup>nd</sup> order model (MISO)

$$\begin{array}{c} \varphi^T(3).\theta = y(3) \\ \vdots = \vdots \\ \varphi^T(6).\theta = y(6) \end{array} \Rightarrow \varphi^T.\theta = y \Rightarrow \theta^* = (\varphi'\varphi)^{-1} \varphi' y$$

# Implications of existence of noise

## ■ In real case




## ■ Then

- Solution of parameter estimation *NOT* uniquely defined
- Solution depends on
  - ☐ Model structure
  - ☐ Excitation signal for identification
  - ☐ Measurement quality
  - ☐ Parameter estimation procedure

**Stochastic problem**


# Implication of existence of noise

## ■ Factors determining parameter estimation accuracy



# Implication of existence of noise

## ■ 1. Model structure




# Implications of existence of noise

## ■ 1. Model structure


### □ Deterministic part

#### ■ Example input-output representation



### □ Deterministic + stochastic part


#### ■ Figure out where noise comes into system



Signal flow for different input-output models (SISO)

# Implications of existence of noise


- 1. Model structure
  - Deterministic + stochastic part
    - Example state-space representation



Signal flow in state-space representation

# Implication of existence of noise

## ■ Parameter estimation method



# Implications of existence of noise

## ■ 2. Parameter estimation method

### □ Discussed methods

- Linear Regression (LR)
- Prediction Error Method (PEM)
- Bayesian Approach




# Implications of existence of noise

## □ Linear Regression (LR)

### ■ Model structure

$$y(t) = \phi^T(t)\theta + e(t)$$



### ■ Minimization of Squared Sum of Errors (SSE)

$$Q_N = \sum_1^N e(t)e^T(t) = \sum_1^N \left( y(t) - \phi^T(t)\hat{\theta} \right) \left( y(t) - \phi^T(t)\hat{\theta} \right)^T$$

### ■ Analytical solution

$$\hat{\theta} = \left[ \sum_1^N \phi(t)\phi^T(t) \right]^{-1} \sum_1^N \phi(t)y(t)$$

# Implications of existence of noise

## □ Prediction Error Method (PEM)

### Output Error model structure (OE)

- Covariance of prediction error

$$Q_N = \sum_1^N \varepsilon(t, \theta) \varepsilon^T(t, \theta)$$

- Prediction error

$$\varepsilon(t, \theta) = y(t) - \hat{y}(t|t-1) = H_{IO}^{-1}(q^{-1}, \theta) [y(t) - G_{IO}(q^{-1}, \theta) \cdot u(t)] \approx e(t)$$


- Optimal predictor

$$\hat{y}(t|t-1, \theta) = L_1(q^{-1}, \theta) \cdot y(t) + L_2(q^{-1}, \theta) \cdot u(t)$$

with

$$L_1(q^{-1}, \theta) = I - H_{IO}^{-1}(q^{-1}, \theta)$$

$$L_2(q^{-1}, \theta) = H_{IO}^{-1}(q^{-1}, \theta) \cdot G_{IO}(q^{-1}, \theta).$$




# Implications of existence of noise

## ■ Cost function

- $V_N(\theta) = \Lambda_N(\theta)^{-1} \text{trace}(Q_N(\theta))$

- $V_N(\theta) = \det(Q_N(\theta))$

- $$\text{Lik}(\theta) = \frac{1}{(2\pi)^{N \cdot n_y / 2} [\det(\Lambda(\theta))]^{N/2}} \exp\left(-\frac{1}{2} \sum_{t=1}^N \varepsilon^T(t, \theta) \Lambda_N^{-1}(\theta) \varepsilon(t, \theta)\right)$$


$$p(y(1) \dots y(N) | \theta)$$

## ■ Optimal parameter estimation $\hat{\theta}^*$

$$\hat{\theta}^* = \arg \min_{\theta} V_N(\theta)$$

- $V_N(\theta)$  is nonlinear in the parameters  $\theta$

- $\rightarrow$  Iterative search

- $\rightarrow$  Importance initial values

# Implications of existence of noise


## □ Prediction Error Method

### State-space model structure

#### ■ Covariance of Estimation error

$$\Sigma(t+1|t) = E \left\{ [x(t+1) - \hat{x}(t+1|t)][x(t+1) - \hat{x}(t+1|t)]^T \right\}.$$

#### ■ Optimal predictor



$$\left. \begin{aligned} \hat{x}(t+1|t) &= F(\theta)\hat{x}(t|t-1) + G_u(\theta)u(t) + K(t)[y(t) - H(\theta)\hat{x}(t|t-1)] \\ \Sigma(t+1|t) &= F(\theta)\Sigma(t|t-1)F^T(\theta) + G_v(\theta)R_v(\theta)G_v^T(\theta) - K(t)Q(t)K^T(t) \\ K(t) &= [F(\theta)\Sigma(t|t-1)H^T(\theta) + G_v(\theta)R_{vr}(\theta)]Q^{-1}(t) \\ Q(t) &= H(\theta)\Sigma(t|t-1)H^T(\theta) + R_r(\theta), \end{aligned} \right\}$$

Kalman  
filter

# Implications of existence of noise

## □ Bayesian approach

- A posteriori probability function

$$p(\theta|y(1)...y(N)) = \frac{p(y(1)...y(N)|\theta)p(\theta)}{p(y(1)...y(N))}$$


- Option 1: Maximize the A Posteriori Probability (MAP)
- Option 2: Use Kalman-filter, assuming  $\theta$  to be state variable

$$\left. \begin{array}{l} \begin{bmatrix} x(t+1) \\ \theta \end{bmatrix} = \begin{bmatrix} F(\theta) \cdot x(t) + G_u(\theta) \cdot u(t) \\ \theta \end{bmatrix} \\ y(t) = H(\theta) \cdot x(t). \end{array} \right\} \text{Augmented state}$$

- $\rightarrow$  Nonlinear  $\rightarrow$  Extended Kalman-filter


# Implication of existence of noise

## ■ Factors determining parameter estimation accuracy




# Implication of existence of noise

## ■ Factors determining parameter estimation accuracy



# Implication of existence of noise

## ■ Factors determining parameter estimation accuracy





# Online system identification example

## ■ Question

### □ Which combination of...

- Model order
- Model structure
- Parameter estimation procedure

### □ ... yields

- Physically meaningful parameters
- Robust against
  - Measurement noise
  - Process simplification
  - Unmeasured solar gains



# Online system identification example

## ■ Methodology

### □ 'Measurement data'

- 200 Monte-Carlo simulations with 3<sup>rd</sup> order model
  - Different  $T_{\text{amb}}$ -profiles
  - Same  $Q_{\text{solar}}$ -profiles
  - Given variance for measurement noise
    - Temperatures: variance  $0.01 \text{ }^{\circ}\text{C}^2$ , read-out accuracy:  $0.1 \text{ }^{\circ}\text{C}$
    - Heating power: variance  $0.25 \text{ kW}^2$ , read-out accuracy:  $0.2 \text{ kW}$
  - Simulation time: 21 days
  - Sampling time: 5 minutes
- → For each set of data: parameter estimation

# Online system identification example

## ■ Methodology

### □ Parameter estimation methods

#### ■ Offline


- Least Squares
- Prediction Error Method – Output Error
- Prediction Error Method – Kalman Filter Predictor

#### ■ Online


- Recursive least squares
- Recursive maximum likelihood
- Extended Kalman filter
- Extended Kalman filter + RML as predictor

# Online system identification example

## Offline: results least squares




3<sup>rd</sup> order model  
Least Squares




2<sup>nd</sup> order model  
Least Squares

# Online system identification example

## Offline: results PEM – Output Error




3<sup>rd</sup> order model  
Prediction Error Method  
Output error model structure  
Maximum Likelihood



2<sup>nd</sup> order model  
Prediction Error Method  
Output error model structure  
Maximum Likelihood

# Online system identification example


## Offline: results PEM – Kalman filter predictor



# Online system identification example


## ■ Online: results

### □ Example: Recursive Maximum Likelihood (RML)




# Online system identification example

## ■ Online: results





# Parameter estimation



# Parametric uncertainty

## ■ Estimator properties

### □ Unbiased estimator

$$E(\hat{\theta}) = \theta^*$$

### □ Efficient estimator

$$F^{-1}(\hat{\theta}) \leq C(\hat{\theta}) \rightarrow F^{-1}(\hat{\theta}) \approx C(\hat{\theta})$$

- With the Variance-Covariance matrix → Confidence region!

$$C(\hat{\theta}) = E\left((\hat{\theta} - \theta^*)(\hat{\theta} - \theta^*)^T\right)$$

As small as possible!


- And the Fisher Information matrix

$$F(\hat{\theta}) = \frac{1}{\sigma^2} \sum_{i=1}^{n_m} \left[ \frac{\partial y(x_i, \theta)}{\partial \theta} \right]_{\theta=\hat{\theta}} \left[ \frac{\partial y(x_i, \theta)}{\partial \theta} \right]_{\theta=\hat{\theta}}^T$$

As large as possible!

### □ Gaussian distributed


$$\hat{\theta} \sim N(\theta^*, F^{-1}(\theta^*))$$



# Parametric uncertainty

## ■ Estimator properties

- If additive, independent, Gaussian distributed noise @ output



- And for a large number of measurement data
- Then the Fisher Information matrix can be approximated by:


$$F(\hat{\theta}) \approx \frac{1}{MSE} J^T J$$

- With the mean squared error  $MSE = \frac{e^T e}{n_m - n_\theta}$

- And  $J^T J$  the Hessian approximation of the cost function at  $\hat{\theta}$

# Parameter uncertainty

## ■ Factors determining parameter estimation accuracy



# Parameter uncertainty

## ■ Quality of parameter estimation depends on:

- Measured variables: MISO versus MIMO
  - Measurement quality: measurement noise variance
  - Amount of disturbances: input noise variance
  - Model order: 3<sup>rd</sup> versus 2<sup>nd</sup> order
  - Parameter estimation method
    - ARX → Least Squares (LS)
    - Output Error (OE) → Prediction Error Method (PEM)
    - State Prediction Error with Kalman filter (KF) → PEM
  - Excitation signal
- } Given
- } To be selected

# Online system identification example

## ■ 5. Model validation


### □ Parameter values

	Hausmodell 3 <sup>er</sup> Ord.	Hausmodell 2 <sup>er</sup> Ord.
$V_H$	1.28 [m <sup>3</sup> ]	1 [m <sup>3</sup> ]
$\kappa_{WB}$ bzw. $\kappa_{WR}$	1160 [W/K]	1100 [W/K]
$m_B c_B$	455.10 <sup>5</sup> [J/K]	-
$\kappa_B$	6155 [W/K]	-
$\kappa_G$	260 [W/K]	260 [W/K]
$\tau_G$	240 [h]	240 [h]
$\Delta T_{Stat}$	3.3 [K]	3.3 [K]


# Online system identification example

## ■ 5. Model validation

### □ Time domain



Comparison of measured zone temperature with simulation results from 2<sup>nd</sup> and 3<sup>rd</sup> order model.



Comparison of measured return water temperature with simulation results from 2<sup>nd</sup> and 3<sup>rd</sup> order model.

- Both: Mean zone temperature correctly predicted
- Both: Variations due to solar radiation not predicted



## ■ 6. Evaluation control performance

### □ Objectives

- Thermal comfort & cost efficiency

→ prediction hourly  $Q_{\text{dem}}$  required... with available sensors

### □ In case of floor heating systems

- $Q_{\text{dem}}$  depends on difference mean zone temperature  $T_{\text{zone}}$  and mean ambient air temperature  $T_{\text{amb}}$
- Fast variations for  $T_{\text{zone}}$  due to solar radiation can not be cancelled out due to inherent inertia of floor heating system

### □ Conclusion

- Both models fit purpose as hourly  $Q_{\text{dem}}$  is accurately predicted!
- 2<sup>nd</sup> order model better suited for online identification



# References


- Bianchi, M. (2006). **Adaptive Modellbasierte Prädiktive Regelung einer Kleinwärmepumpenanlage**, Institut für Mess- und Regeltechnik, ETH Zürich, p. 235.
- Parameter and State Estimation course, OPTEC, K.U.Leuven, 30-31 augustus 2010, [www.kuleuven.be/optec](http://www.kuleuven.be/optec)

# Applications in building control

- Applications in building control
  - Heating curve control
  - MPC for heavy-weight solar building
  - MPC for heat pump system with floor heating
  - MPC for ground coupled heat pump system
  - MPC for multizone building



# Ground coupled heat pump example



## ■ 1. Control objectives

- Thermal comfort at building side
- Minimal electricity cost
- Thermal balance at borefield side


# Ground coupled heat pump example

## ■ 1. Control objective

### □ A. Minimal electricity cost

$$COP = \frac{\dot{Q}_{supply}}{P_{compressor}}$$

$$COP_{max} = \frac{T_{supply}}{T_{supply} - T_{source}}$$





→ Brine water temperature needed for short-term control

# Ground coupled heat pump example

## ■ 1. Control objectives


### □ B. Thermal balance at borefield side



→ Measure for stored energy needed for long-term control

# Ground coupled heat pump example


## ■ 2. Model input and outputs



# Ground coupled heat pump example

## ■ 2. Physical model

### □ Case borefield



# Ground coupled heat pump example


## ■ 2. Physical model

### □ Heat transfer processes

- Between brine and ground: convection + conduction
- In the ground: conduction

$$Q_b = \frac{T_b - T_f}{R_b}$$



$$T_f = T_g - \frac{Q_b}{4\pi k_g H} \left( \ln(t) + \ln\left(\frac{4\alpha}{r_b^2}\right) \right) - \frac{Q_b}{H} R_b$$





# Ground coupled heat pump example

## 3. Model structure



Grey-box model


TRNSYS type557b

Matlab


# Ground coupled heat pump example

## ■ 3. Model structure

### □ RC-network representation



### □ State space formulation



$$\begin{aligned} \dot{x} &= Ax + Bu \\ y &= Cx \end{aligned}$$

$$\begin{pmatrix} \dot{T}_1 \\ \dot{T}_2 \\ \dot{T}_3 \end{pmatrix} = \begin{pmatrix} -\frac{1}{R_1 C_1} & \frac{1}{R_1 C_1} & 0 \\ \frac{1}{R_1 C_2} & -\left(\frac{1}{R_1 C_2} + \frac{1}{R_2 C_2}\right) & \frac{1}{R_2 C_2} \\ 0 & \frac{1}{R_2 C_3} & -\left(\frac{1}{R_2 C_3} + \frac{1}{R_3 C_3}\right) \end{pmatrix} \begin{pmatrix} T_1 \\ T_2 \\ T_3 \end{pmatrix} + \begin{pmatrix} -\frac{1}{C_1} & 0 \\ 0 & 0 \\ 0 & \frac{1}{R_3 C_3} \end{pmatrix} \begin{pmatrix} \dot{Q}_{bf} \\ T_g \end{pmatrix}$$

$$T_f = \begin{pmatrix} 1 & 0 & 0 \end{pmatrix} \begin{pmatrix} T_1 \\ T_2 \\ T_3 \end{pmatrix}$$


# Ground coupled heat pump example

## ■ 4. Parameter estimation

### □ Identification data

input variables  $\rightarrow$

$\dot{m}, T_{f,inlet} \dots$




$\rightarrow$  output variables


$\dot{Q}_b, T_{f,outlet}, T_{bf}$

TRNSYS Type557b


RC-model input



RC-model output 1



RC-model output 2



# Ground coupled heat pump example

## ■ 4. Parameter estimation

- Model with  $2N$  parameters
- Prediction Error Method & least squares
  - $m$  measurements  $y(t)$
  - $m$  model outputs  $y_{\text{mod}}(t)$
  - $m$  model errors  $e(t)$


$$\theta^* = \arg \min_{\theta} \frac{1}{2} e^T e \quad \text{with}$$

$$e = \begin{pmatrix} y_{\text{mod}}(t_0) - y(t_0) \\ y_{\text{mod}}(t_1) - y(t_1) \\ \vdots \\ y_{\text{mod}}(t_m) - y(t_m) \end{pmatrix}$$

- → Nonlinear optimization problem
  - Solved with gradient-based method
  - Importance of choice initial value

# Gradient-based methods

## ■ Principle



$$\hat{\theta}(k+1) = \hat{\theta}(k) + \Delta\theta$$

$$J = \begin{pmatrix} \frac{\partial y(t_1)}{\partial \theta_1} & \frac{\partial y(t_1)}{\partial \theta_2} & \dots & \frac{\partial y(t_1)}{\partial \theta_{Np}} \\ \frac{\partial y(t_2)}{\partial \theta_1} & \frac{\partial y(t_2)}{\partial \theta_2} & \dots & \frac{\partial y(t_2)}{\partial \theta_{Np}} \\ \vdots & \vdots & \ddots & \vdots \\ \frac{\partial y(t_{Nm})}{\partial \theta_1} & \frac{\partial y(t_{Nm})}{\partial \theta_2} & \dots & \frac{\partial y(t_{Nm})}{\partial \theta_{Np}} \end{pmatrix}$$

Jacobian matrix

- Steepest gradient  $\Delta\theta = -J e$
- Gauss-Newton  $\Delta\theta = -(J^T J)^{-1} J e$
- Levenberg-Marquardt  $\Delta\theta = -(J^T J + \lambda)^{-1} J e$

# Ground coupled heat pump example


## ■ 4. Parameter estimation

### □ Initial values based on theory of heat conduction

$$\frac{\alpha t}{r^2} \approx 0.8$$


$$R = \frac{1}{2\pi k_g H} \ln\left(\frac{r}{r_b}\right)$$

$$C = c_g \pi (r^2 - r_b^2) H$$




# Ground coupled heat pump example

## ■ 5. Model validation temperature $T_{bf}$



Mean borefield temperature




Error on mean borefield temperature


order = 1 & time<sub>ID</sub> = 1/2 year

# Ground coupled heat pump example

## ■ Evaluation models for mean borefield temperature



Mean borefield temperature





Error on mean borefield temperature

order = 2 & time<sub>ID</sub> = 1/2 year



# Ground coupled heat pump example


## ■ Evaluation models for mean fluid temperature $T_f$




order = 4 & time<sub>id</sub> = 1/2 year

# Ground coupled heat pump example

## ■ Evaluation models for mean fluid temperature $T_f$



Fluid temperature



Error on fluid temperature

order = 5 & time<sub>id</sub> = 1/2 year


# Ground coupled heat pump example

## ■ Results


- Optimal model order: to be determined
- Problems with extrapolation
- $\hat{\theta}^*$  depends on identification data set

# Parameter uncertainty

## ■ Factors determining parameter estimation accuracy




# Choice of identification data




# Choice of identification data

## ■ Define dynamics of interest



Step response of system  
System time constants




Bode plot of system  
Frequency range of interest

$$\frac{1}{\tau_{\min}} = f_{\text{sys,max}}$$
$$\frac{1}{\tau_{\max}} = f_{\text{sys,min}}$$


# Choice of identification data

- Excite frequencies of interest



# Choice of identification data


- Excite frequencies of interest






# Choice of identification data

- Excite frequencies of interest




# Choice of identification data

- Excite frequencies of interest




# Choice of identification data

- Excite frequencies of interest




# Choice of identification data


## ■ 'Persistent excitation'



Step response of system



Bode plot of system




# Ground coupled heat pump example

## ■ 4. Parameter estimation

### □ ... new set of identification data

Identification data


- Simulation



- 4 sets: period of 3 months, 6 months, 1 year, 10 year

# Ground coupled heat pump example

- ... and extra set of model structures



$$\frac{T'_f}{Q'} = \frac{b_z s^z + b_{z-1} s^{z-1} + \dots + b_0}{a_p s^p + a_{p-1} s^{p-1} + \dots + a_0}$$

$$g(t^*, \beta) = \frac{1}{2} \int_0^1 d\eta \int_0^1 \left[ \frac{\text{erfc}(r^+ / 2\beta\sqrt{t^*})}{r^+} - \frac{\text{erfc}(r^- / 2\beta\sqrt{t^*})}{r^-} \right] d\xi$$

Diffusion in  
semi-infinite  
medium

$$\frac{T'_f}{Q'} = \frac{b_z (\sqrt{s})^z + b_{z-1} (\sqrt{s})^{z-1} + \dots + b_0}{a_p (\sqrt{s})^p + a_{p-1} (\sqrt{s})^{p-1} + \dots + a_0}$$

# Ground coupled heat pump example


## ■ 5. Model validation

- Parameter values: physical?
- Confidence interval parameters
- Cross-validation in time domain
- Modal analysis in frequency domain
- Error analysis


# Ground coupled heat pump example

## ■ 5. Model validation

### □ Time domain



input  $u_{\text{val}}$



TRNSYS output  $y_{\text{val}}$


Validation data set



# Ground coupled heat pump example

## ■ 5. Model validation

### □ Time domain




Validation result RC-model (detail)

# Ground coupled heat pump example

## ■ 5. Model validation

### □ Frequency domain

- Bode-plots RC-model/ TRNSYS-model





Frequencies  
covered by  
ID data

# Ground coupled heat pump example

## 6. Extrapolation properties


### Frequency domain



# Ground coupled heat pump example

## ■ 6. Extrapolation properties

### □ Time domain



# Ground coupled heat pump example

## ■ 7. Model selection for MPC


RC-model	s-transfer function	$\sqrt{s}$ -transfer function
✓ state space	✓ state space	✗ no state space
✓ excellent validation	✗ bad validation	✓ good validation
✗ no extrapolation	✗ no extrapolation	✓ good extrapolation

# References

- Verhelst, C., Vandersteen, G., Schoukens, J., Helsen, L. (2009). **A linear dynamic borehole model for use in model based predictive control**. Proceedings of EFFSTOCK 2009. Effstock 2009. Stockholm, Sweden, 14-17 June 2009.
- Kollár, I. (2004-2007). **Frequency Domain System Identification Toolbox V3.3 for Matlab**, Gamax Ltd, Budapest
- Pintelon, R., Schoukens, J., Pauwels, L., Van Gheem, E., (2005). **Diffusion systems: stability, modeling and identification**, IEEE Transactions on Instrumentation and Measurement, vol.54, no.5, pp.2061-2067.

# Applications in building control

- Applications in building control
  - Heating curve control
  - MPC for heavy-weight solar building
  - MPC for heat pump system with floor heating
  - MPC for ground coupled heat pump system
  - MPC for multizone building



# Multizone control



Pictures of the office building, Wellen, Belgium, used as case study




# Multizone control




Valves of circuits towards concrete-core-activation of different zones

# Multizone control



# Multizone control


- Simulation model
  - Trnsys building simulation software



10-zone-simulation model

# Multizone control


## Physical model for MPC



Figuur 40: Volledig RC-schema

De weerstands- en capaciteitswaarden die horen bij dit schema zijn te vinden in Bijlage 2.


Advanced HVAC Control,




Figuur 41: Vereenvoudigd RC-schema

# Multizone control

## ■ Control scheme




## ■ Control performance evaluation



Upper: Optimal heat input profile for concrete-core activation (blue) and floor heating (green), given a day-night electricity rate tariff (red) and occupancy profile (cyan)  
Lower: Calculated optimal supply water temperatures (blue and green) and zone temperature (red)



# Multizone control



# Multizone control

## ■ Control performance evaluation

	Mean PPD (-)	Energy cost (€)	Electricity consumption (kWh)	Heat production (kWh)	COP (-)
Current control	5.1	257	1156	5806	5.0
MPC without low-level control	6.6	133	976	5070	5.2
MPC with low-level control	5.1	158	1023	5413	5.3



# Multizone control

- Trade-off between
  - Model accuracy
  - Cost monitoring
- This case: Despite huge simplifications
  - Multizone → single zone
  - No ventilation losses
  - No internal gains
  - No solar gains
- ... still an improvement in control performance compared to conventional controller!

# References

- Bax P.J., Krishnasing Y., 2010, **Notarisgebouw in Wellen: modellering, experimentele validatie en ontwikkeling MPC-regeling**, Thesis Master Energy, K.U.Leuven

# Outline

- Introduction
- Framework of Model Predictive Control
- Development of control relevant model
- Applications in building control
- **Conclusion**

# Conclusion

- ❑ Model information
  - Physical foundation makes sense!
- ❑ Model structure
  - Simplify as much as possible (but not more)
- ❑ Parameter estimation
  - Noise models
  - Excitation signal
- ❑ Model selection
  - Analyse control performance
  - Even with simplified models, significant improvement of control performance possible